



CERTIFICATE NO.

BPAT-2026-00000

Revision A · Issued 16/10/2026

01271 599018 · barnstaplepat@gmail.com · <https://barnstaplepattesting.co.uk>

PAT Testing Certificate

In-service inspection and testing of electrical equipment

CUSTOMER

Sample Customer Ltd

DATE OF TESTING

15/10/2026

TESTED BY

BPAT tester

SITE TESTED

Main office, Example Street, Barnstaple

JOB REFERENCE

JOB-SAMPLE

TEST INSTRUMENT

Seaward PrimeTest 50 · S/N SAMPLE

Calibration due 01/03/2027

6

ITEMS TESTED

5

PASSED

1

FAILED

15/10/2027

EARLIEST NEXT TEST

Action needed — failed items

ID	APPLIANCE	LOCATION	REASON	ACTION TAKEN
SAM-0006	4-way extension lead	Office	Plug cover undamaged, pins not bent: Cracked plug top	Withdrawn from use — Cut off plug and label applied (told: Office manager)

Declaration

I certify that the electrical equipment listed in the attached register was inspected and tested on the date(s) shown, at the premises stated, in accordance with the IET Code of Practice for In-service Inspection and Testing of Electrical Equipment (5th Edition), as part of the duty holder's arrangements under the Electricity at Work Regulations 1989. The results recorded are those found at the time of testing.

Procedure: BPAT procedure v1 (Visual checks: HSE INDG236 Maintaining portable electric equipment in low-risk environments. Test sequences: Seaward PrimeTest 50 manual.)

BPAT tester · Tester · 16/10/2026

Customer (not signed)

Asset register and test results

Ticks and crosses are the PrimeTest 50's own pass/fail indication for each test. N/A = not applicable.

#	ID	APPLIANCE	LOCATION	CLASS	VISUAL	ELECTRICAL TESTS	RESULT	NEXT TEST
1	SAM-0001	Kettle	Kitchen	I	✓ OK 14/14 OK	Class I - 500 V ✓ Earth continuity ✓ Insulation resistance	PASS	15/10/2027
2	SAM-0002	Microwave	Kitchen	I	✓ OK 14/14 OK	Class I - 500 V ✓ Earth continuity ✓ Insulation resistance	PASS	15/10/2027
3	SAM-0003	Monitor	Office	II	✓ OK 14/14 OK	Class II - 500 V ✓ Insulation resistance	PASS	15/10/2027
4	SAM-0004	Laptop charger	Office	II	✓ OK 14/14 OK	Class II - 500 V ✓ Insulation resistance	PASS	15/10/2027
5	SAM-0005	Desk lamp	Office	II	✓ OK 14/14 OK	Class II - 500 V ✓ Insulation resistance	PASS	15/10/2027
6	SAM-0006	4-way extension lead	Office	I	✗ Defect 13/14 OK	Class I - 500 V ✓ Earth continuity ✓ Insulation resistance	FAIL	—

Visual inspection — every item checked

- 1. Lead free from fraying, cuts or heavy scuffing
- 2. Plug cover undamaged, pins not bent
- 3. No tape joining or repairing the lead
- 4. No coloured inner wires showing where the lead enters the plug
- 5. Equipment casing undamaged, no loose parts or screws
- 6. No signs of overheating (burn marks or staining on plug, lead or equipment)
- 7. Suitable for where it is used and stored (not wet, dusty or at risk of spills)
- 8. Lead not trapped under furniture or in floor boxes
- 9. Plug internal: no internal damage, overheating or water damage
- 10. Plug internal: correct, genuine fuse fitted (not wire or a nail)
- 11. Plug internal: wires, including earth, on the correct terminals
- 12. Plug internal: terminal screws tight
- 13. Plug internal: cord grip holding the outer sheath firmly
- 14. Plug internal: no bare wire visible except at the terminals

ID	APPLIANCE	1	2	3	4	5	6	7	8	9	10	11	12	13	14
SAM-0001	Kettle	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
SAM-0002	Microwave	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
SAM-0003	Monitor	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
SAM-0004	Laptop charger	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
SAM-0005	Desk lamp	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
SAM-0006	4-way extension lead	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓

Defect notes

- SAM-0006 — Plug cover undamaged, pins not bent: Cracked plug top